

2021 Lead in Drinking Water Statement of Assurance

South Hunterdon Regional School District
301 Mt. Airy-Harbourton Road
Lambertville, New Jersey

Sent via e-mail: Leadtesting@doe.state.nj.us

To whom it may concern:

On Saturday, March 26, 2022, the South Hunterdon Regional School District conducted lead in drinking water sampling. The lead in drinking water sampling was conducted in accordance with the New Jersey Schools Lead in Drinking Water Regulations; N.J.A.C. 6A:26-1.2;12.4 and the USEPA "3 T's for Reducing Lead in Drinking Water in Schools". A total of one hundred and forty-eight (148) samples were collected from all drinking water outlets to which a student or staff member has or may have access to in all South Hunterdon Regional School District facilities. Analytical results for all samples with the exception of three (3) were below the action level of 15ppb. Proper remedial actions were taken for the 6 sampling locations that tested above the action level and follow-up sampling was conducted to determine lead levels below the action level of 15ppb.

Name of NJ Certified Laboratory who performed the analytical testing and certification number:

Name: Alpha Analytical Inc Certification Number: MA015

Please see the below checklist indicating all required steps were taken to meet the regulatory requirements of N.J.A.C 6A:26 1.2 and 12.4.

- ✓ QAPP signed by all parties involved in sampling (Program Manager, Project Manager, Individual School Project Officers, Laboratory Manager, Laboratory QA Officer)
- ✓ Sampling conducted in accordance with a Lead Sampling Plan
- ✓ Completed Plumbing Profile (Attachment B)
- ✓ Completed Water Outlet Inventory (Attachment C)
- ✓ Completed Filter Inventory (Attachment D)
- ✓ Completed Flushing Log (Attachment E)